



Certificate No. : L2939-200914

財團法人全國認證基金會
Taiwan Accreditation Foundation

Certificate of Accreditation

This is to certify that

WHOLE POWER CO., LTD.

High Voltage Testing Laboratory

No.47-2, Fanpolin, Xiban Li, Sanchie District, New Taipei City, Taiwan, R.O.C.

is accredited in respect of laboratory

Accreditation Criteria : ISO/IEC 17025:2017 ; CNS 17025:2018
Accreditation Number : 2939
Originally Accredited : October 22, 2014
Effective Period : October 22, 2020 to October 21, 2023
Accredited Scope : Testing Field, see described in the Appendix

Chung-Lin Wang

Chung-Lin Wang
President, Taiwan Accreditation Foundation
Date : September 14, 2020



Certificate No. : L2939-200914

財團法人全國認證基金會
Taiwan Accreditation Foundation

Accreditation Number : 2939

Laboratory Head : HUANG, Yi-Heng

■ 31.02 Electrical power equipment

Oil immersed Power distribution transformer
E006

1. Measurement of winding resistance
2. Measurement of voltage ratio and Polarity test
3. Measurement of short-circuit impedance and load loss
4. Measurement of no-load loss and current
5. Separate source AC withstand voltage test
6. Induced AC voltage tests
7. Insulation resistance test
8. Temperature rise tests
9. Audible sound-level measurements
10. Lightning impulse voltage test

CNS 598(2017)

TPC C001(2020)

TPC C033 (2018)

TPC C035 (2010)

TPC Y065 (2012)

TPC Y066 (2006)

TPC Y205 (2012)

TPC Y163 (2019)

1 ϕ , 13.8 kV Max., 60 Hz, 167 kVA Max.

Approval Signatory: CHIANG, Chih-Hao; CHOU, Hsien-Jen; HUANG, Yi-Heng

Testing Site: 1.No.47-2, Fanpolin, Xiban Li, Sanchie District, New Taipei City, Taiwan, R.O.C.; 2.N0.47-3, Fanpolin, Xiban Li, Sanchie District, New Taipei City, Taiwan, R.O.C.

(Null below)