



Certificate No. : L2939-170728

財團法人全國認證基金會
Taiwan Accreditation Foundation

Certificate of Accreditation

This is to certify that

WHOLE POWER CO., LTD.

High Voltage Testing Laboratory

No.47-2, Fanpolin, Xiban Li, Sanchie District, New Taipei City, Taiwan, R.O.C.

is accredited in respect of laboratory

Accreditation Criteria : ISO/IEC 17025: 2005
Accreditation Number : 2939
Originally Accredited : October 22, 2014
Effective Period : October 22, 2017 to October 21, 2020
Accredited Scope : Testing Field, see described in the Appendix

Chung-Lin Wang
President, Taiwan Accreditation Foundation
Date : July 28, 2017



Certificate No. : L2939-170728

財團法人全國認證基金會
Taiwan Accreditation Foundation

Accreditation Number : 2939

Laboratory Head : HUANG, Yi-Heng

■ 31. 02 Electrical power equipment
Oil immersed Power distribution transformer
E006

1. Measurement of winding resistance
2. Measurement of voltage ratio
3. Measurement of short-circuit impedance and load loss
4. Measurement of no-load loss and current
5. Separate source AC withstand voltage test
6. Induced AC voltage tests
7. Insulation resistance test
8. Temperature rise tests
9. Audible sound-level measurements
10. Lightning impulse voltage test
11. Polarity test

CNS 598(1996)

CNS 599(1996)

TPC C001(2015)

TPC C033 (2012)

TPC C035 (2010)

TPC Y065 (2012)

TPC Y066 (2006)

TPC Y205 (2012)

1 ϕ , 13.8 kV Max., 60 Hz, 167 kVA Max.

Approval Signatory: CHIANG, Chih-Hao; CHOU, Hsien-Jen; HUANG, Yi-Heng

(Null below)