



Certificate No. : L2939-211104

財團法人全國認證基金會
Taiwan Accreditation Foundation

Certificate of Accreditation

This is to certify that

WHOLE POWER CO., LTD.
High Voltage Testing Laboratory

No.47-7, Fanpolin, Xiban Li, Sanchie District, New Taipei City, Taiwan, R.O.C.

is accredited in respect of laboratory

Accreditation Criteria : ISO/IEC 17025:2017 ; CNS 17025:2018
Accreditation Number : 2939
Originally Accredited : October 22, 2014
Effective Period : October 22, 2020 to October 21, 2023
Accredited Scope : Testing Field, see described in the Appendix



Ching-Chang Lien
President, Taiwan Accreditation Foundation
Date : November 04, 2021



Certificate No. : L2939-211104

財團法人全國認證基金會
Taiwan Accreditation Foundation

Accreditation Number : 2939

Laboratory Head : LEE, Wen-Jung

31.02 Electrical power equipment
Oil immersed Power distribution transformer
E006

1. Measurement of winding resistance
2. Measurement of voltage ratio and Polarity test
3. Measurement of short-circuit impedance and load loss
4. Measurement of no-load loss and current
5. Separate source AC withstand voltage test
6. Induced AC voltage tests
7. Insulation resistance test
8. Temperature rise tests
9. Audible sound-level measurements
10. Lightning impulse voltage test

CNS 598 (2017)

TPC C001 (2020)

TPC C033 (2018)

TPC C035 (2010)

TPC Y065 (2012)

TPC Y066 (2006)

TPC Y205 (2012)

TPC Y163 (2019)

1 ϕ , 13.8 kV Max., 60 Hz, 167 kVA Max.

Approval Signatory: CHIANG, Chih-Hao; CHOU, Hsien-Jen

Testing Site: 1.No.47-7, Fanpolin, Xiban Li, Sanchie District, New Taipei City, Taiwan, R.O.C.; 2.No.47-8, Fanpolin, Xiban Li, Sanchie District, New Taipei City, Taiwan, R.O.C.

(Null below)